

## Pre Inspection Checklist

### Gate

- Does the gate open outwards, away from the pool?
- Is the top of the gate latch at least 1500mm from the ground?
- Does the gate self close and latch from any position?
- Does the gate stay closed when pulled?
- Is the gap below the bottom of the gate less than 100mm?
- Are the hinges 900mm apart, or non-climbable?
- There are no items to prop the gate open

### Fence

- Are all fence panels in place?
- Are all screws, nails and fixings secure?
- Is the fence free of sharp edges?
- Is the fence at least 1200mm high?
- Is the gap below the bottom of the fence less than 100mm?
- Are there any gaps in the fence bars more than 100mm?
- Are climbable horizontal rails at least 900mm apart?

### Fence Strength & Rigidity

- If you squeeze the vertical bars, does the gap remains less than 100mm on either side?

### Non Climbable Zone

- Are trees at least 900mm from the pool fence?
- Are climbable items at least 900mm from the pool fence?
- Is there a clear zone where the pool fence intersects with another fence?
- Is there a clear area of 300mm inside the pool fence?

### CPR Sign

- Is there a clearly displayed CPR sign?

### Windows and Doors

- Is there any direct access from the house to the pool area?
- Do windows that open directly to the pool area open less than 100mm

#### Disclaimer

This checklist is intended to provide a guideline to customers of Queensland Pool Solutions of the most common problems found during inspections and to enable remedial work to be carried out prior to the actual pool safety inspection. The checklist should not be considered an alternative or substitute for an inspection by a licensed pool safety inspector.